



**REMOTE FAN ASSEMBLY**

Airflow (nom)  
600cfm/1019m3/hr  
200-250VAC, 50/60Hz

Install out of earshot of the enclosure.

Connect to Enclosure Exhaust using duct rated for 1000cfm/1700m3/hr

Fan may feed into a ceiling void or building air return duct.

Wire back to Enclosure Controller fan terminals (see manual).

Fan Wire Terminal - connect through duct to Enclosure Controller fan terminals using 16AWG/1.5mm2 wire

Grommet

Terminal Cover

UNLESS OTHERWISE SPECIFIED:  
DIMENSIONS ARE IN INCHES  
TOLERANCES:  
FRACTIONAL ±  
ANGULAR: MACH ± BEND ±  
TWO PLACE DECIMAL ±  
THREE PLACE DECIMAL ±  
INTERPRET GEOMETRIC TOLERANCING PER:  
MATERIAL  
FINISH  
DO NOT SCALE DRAWING

NAME	DATE
TB	12/10/2016
DRAWN	
CHECKED	
ENG APPR.	
MFG APPR.	
Q.A.	
COMMENTS:	



TITLE:  
**10"/254mm Remote Fan Assembly**

SIZE	DWG. NO.	REV
<b>B</b>	<b>51.RFA.10</b>	<b>02</b>

SCALE: 1:20 SHEET 1 OF 1