


AIRFLOW DIRECTION



0.24 [6] X 0.49 [12]

REMOTE FAN ASSEMBLY

Airflow (nom) 1,200cfm/2000m3/hr
200-250VAC, 50/60Hz

Install out of earshot of the enclosure.

Connect to Enclosure Exhaust using duct rated for 1,500cfm/2,500m3/hr

Fan may feed into a ceiling void or building air return duct.

Wire back to Enclosure Controller fan terminals (see manual).

Fan Wire Terminal - connect through duct to Enclosure Controller fan terminals using 16AWG/1.5mm2 wire

Grommet

Terminal Cover

UNLESS OTHERWISE SPECIFIED:
DIMENSIONS ARE IN INCHES
TOLERANCES:
FRACTIONAL ±
ANGULAR: MACH ± BEND ±
TWO PLACE DECIMAL ±
THREE PLACE DECIMAL ±
INTERPRET GEOMETRIC TOLERANCING PER:
MATERIAL
FINISH
DO NOT SCALE DRAWING

NAME	DATE
TB	12/10/2016
DRAWN	
CHECKED	
ENG APPR.	
MFG APPR.	
Q.A.	
COMMENTS:	

TEMPEST
lighting inc.

TITLE:
11"/280mm Remote Fan Assembly

SIZE	DWG. NO.	REV
B	51.RFA.11	02

SCALE: 1:20 SHEET 1 OF 1